



Compliance Statement

No. 2017-752

Screened Channel, Class E

Company

Galaxy Technology Co., Ltd.
4F, No. 506-4, Yuan-Shan Rd.
Jung-Ho City
Taipei Hsien 235
Taiwan

Channel Identification (2 connector model)

Horizontal Cable:

GA-512014-XX (XX: color)

Patch Cords:

GA-622031-5M-XX

Keystone:

GA-36X229-C6

Patch Panel:

GA-28XX240-C6

Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-T727792-02, DANAK-19/18247

EC Cabling product ID

5069

CS valid until

1 November 2018

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 11 September 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venlighedsvej 4 Tel. +45 72 19 40 00
2970 Hørsholm Fax +45 72 19 40 01
Denmark www.madebydelta.com/cable

