



**Cable ID: AGENDA006-C5EUTP-5M-5**


Date / Time: 04/20/2015 02:28:20 PM  
**Headroom 2.1 dB (NEXT 12-45)**  
**Test Limit: TIA Patch Cord Cat5e 5.0m**  
 Cable Type: Cat 5e UTP  
 Calibration Date: 05/02/2014

Operator: Your Name  
 Software Version: 2.7400  
 Limits Version: 1.9300  
 NVP: 69.0%

**Test Summary: PASS**

Model: DTX-1800  
 Main S/N: 2038005  
 Remote S/N: 2038006  
 Main Adapter: DTX-PC5E/MN  
 Remote Adapter: DTX-PC5E/SR

Length (ft)	[Pair 12]	16
Prop. Delay (ns)	[Pair 36]	25
Delay Skew (ns)	[Pair 36]	1
Resistance (ohms)	[Pair 45]	0.6



Wire Map (T568B)  
**PASS**



Worst Case Margin Worst Case Value

	MAIN	SR	MAIN	SR
<b>PASS</b>				
Worst Pair	12-45		12-45	
<b>NEXT (dB)</b>	2.1		3.7	
Freq. (MHz)	39.8		100.0	
Limit (dB)	45.2		37.8	

	MAIN	SR	MAIN	SR
<b>PASS</b>				
Worst Pair	12		45	
<b>RL (dB)</b>	4.9		6.9	
Freq. (MHz)	27.0		99.0	
Limit (dB)	23.7		18.0	

